

# IL CAN BK-TC-PAC

Order No.: 2718701



http://eshop.phoenixcontact.de/phoenix/treeViewClick.do?UID=2718701

CANopen bus coupler, 24 V DC, bus interface 2 x 5-pos. TWIN-COMBICON connector, complete with accessories (connector and labeling field)

CANOPER

Commercial data	
GTIN (EAN)	4 017918 891237
sales group	K410
Pack	1 pcs.
Customs tariff	85389091
Catalog page information	Page 259 (AX-2009)

#### http://

www.download.phoenixcontact.com Please note that the data given here has been taken from the online catalog. For comprehensive information and data, please refer to the user documentation. The General Terms and Conditions of Use apply to Internet downloads.

## **Product description**

The CANopen fieldbus coupler enables the flexible INTERBUS Inline automation kit to be operated in CANopen networks as well. The fieldbus coupler allows an INTERBUS Inline station to be inserted at any point in a CANopen network. The fieldbus coupler is a slave in the CANopen network and a master in the lower-level INTERBUS Inline local bus.

The address of the CANopen slave can easily be set via DIP switches from outside. The CANopen network is connected via a Twin Combicon connector. The operating voltage for the fieldbus coupler and the electronics can be fed using a separate power connector.

For the CANopen project planning, a regularly updated EDS file (Electronica Data Sheet) is provided in the Product Information Service (see below). The CANopen fieldbus coupler supports the proven INTERBUS Inline diagnostics as well as the typical diagnostics objects for CANopen. Local LEDs enable precise diagnostics.

Please note the following when you configure the system:

The total logic current of all terminals connected to a CANopen network must not exceed the maximum permissible total current of 2 A. Therefore, depending on your configuration, the number of terminal blocks that you can connect may be less than 63.

General data	
Width	85 mm
Height	119.8 mm
Depth	71.5 mm
Weight	240 g
Note on weight specifications	with male connectors
Mounting type	DIN rail
Ambient temperature (operation)	-25 °C 55 °C
Ambient temperature (storage/transport)	-45 °C 85 °C
Permissible humidity (operation)	95 % (no condensation)
Permissible humidity (storage/transport)	95 % (no condensation)
Air pressure (operation)	80 kPa 106 kPa (up to 3000 m above sea level)
Air pressure (storage/transport)	70 kPa 106 kPa (up to 3000 m above sea level)
Degree of protection	IP20
Test section	CANopen/local bus 500 V
Interface	
Fieldbus system	Lokalbus
Name	Inline local bus
Type of connection	Inline data jumper
Transmission speed	500 kBaud
Fieldbus system	CANopen
Name	CANopen
Type of connection	2x 5-pos. TWIN-COMBICON connectors
*!	
	1 MBaud, 500 kBaud, 250 kBaud, 125 kBaud, 50 kBaud, 20 kBaud, 10 kBaud (Can be set via DIP switch or programmed)
Transmission speed	
Transmission speed Address area assignment	kBaud, 10 kBaud (Can be set via DIP switch or programmed)
Transmission speed Address area assignment Name	kBaud, 10 kBaud (Can be set via DIP switch or programmed) 0 63, can be set
Transmission speed  Address area assignment  Name  Type of connection  Power supply for module electronics	kBaud, 10 kBaud (Can be set via DIP switch or programmed)  0 63, can be set  Supply
Transmission speed  Address area assignment  Name  Type of connection	kBaud, 10 kBaud (Can be set via DIP switch or programmed)  0 63, can be set  Supply

Current consumption	max. 1.25 A (from U <sub>BK</sub> )	
Inline potential routing		
Communications power U <sub>L</sub>	7.5 V DC ±5%	
Power supply at U <sub>L</sub>	max. 2 A DC	
Main circuit supply $U_{\scriptscriptstyle M}$	24 V DC -15% / +20% (in acc. with EN 61131-2)	
Power supply at U <sub>M</sub>	max. 8 A DC (Sum of U <sub>M</sub> + U <sub>S</sub> )	
Segment supply voltage U <sub>s</sub>	24 V DC -15% / +20% (in acc. with EN 61131-2)	
Power supply at U <sub>s</sub>	max. 8 A DC (Sum of U <sub>M</sub> + U <sub>S</sub> )	
I/O supply voltage U <sub>ANA</sub>	24 V DC -15% / +20%	
Power supply at U <sub>ANA</sub>	max. 0.5 A DC	

# **Certificates / Approvals**






CUL, GOST, UL Certification

Certification Ex: CUL-EX LIS, UL-EX LIS


Accessorie	e	
Accessories	•	
Item	Designation	Description
Assembly		
3022218	CLIPFIX 35	Snap-on end bracket, for 35 mm NS 35/7.5 or NS 35/15 DIN rail, can be fitted with Zack strip ZB 8 and ZB 8/27, terminal strip marker KLM 2 and KLM, width: 9.5 mm, color: gray
Marking		
0809492	ESL 62X10	Insert strip for laser printer, lettering field: 62 x 10 mm
2727501	IB IL FIELD 2	Labeling field, width: 12.2 mm
Plug/Adapto	er	
2727608	IB IL SCN-8-CP	Inline connector, colored

## **Diagrams/Drawings**


### Connection diagram



### Block diagram



#### Dimensioned drawing



## **FAQs**

## How does the autoconfiguration function on the IL CAN BK-TC bus coupler?

The autoconfiguration function allows the bus coupler to be configured inn the field without any software. The default settings with this function are: a. The receive PDO 1 maps the digital outputs 1 to 64. If fewer digital outputs are connected, fewer are mapped. b. The transmit PDO 1 contains the digital inputs 1 to 64. If fewer digital inputs are connected, fewer are mapped. c. The receive PDO 2 contains analog outputs 1 to 4, if they are available. d. The receive PDO 2 contains analog inputs 1 to 4, if they are available. e. The receive PDO 3 contains analog outputs 5 to 8, if they are available. f. The transmit PDO 3 contains analog inputs 5 to 8, if they are available. g. The receive PDO 4 contains analog outputs 9 to 12, if they are available. h. The transmit PDO 4 contains analog inputs 9 to 12, if they are available. i. All other I/O modules, such as function modules, must be configured manually. To use the autoconfiguration function, proceed as follows: 1. Set all the DIP switches for the address setting (1-7) to "0". 2. Switch the supply voltage of the bus coupler UL off and back on again after the desired I/O modules have been

connected. The "RUN" LED is green and stops flashing when the station has saved the local bus configuration in the memory. The bus coupler does not go "online" on the fieldbus as long as the address is set to "00 00 00 0". 3. Switch off power supply UL. 4. Set the address and baudrate. 5. Switch power supply UL back on.

• What is the switch position of the CANopen fieldbus coupler when it is delivered?

The CANopen fieldbus coupler is supplied with the address 1 and a baudrate of 20 k. (Switch 1,9 = On; all others Off).

## Address

PHOENIX CONTACT Inc., USA 586 Fulling Mill Road Middletown, PA 17057,USA Phone (800) 888-7388 Fax (717) 944-1625 http://www.phoenixcon.com



© 2011 Phoenix Contact Technical modifications reserved;