

POWER-ON COUNTER POWER-ON HOUR METER

1. Easy to install on existing machinery

cables. There is no need to install any

The built-in battery allows the units to be

4. Compact size doesn't take up space

Easy to install even in cramped spaces.

Just attach the dedicated CT to your existing

KC2S Eco-COUNT METER KE2S Eco-HOUR METER

Eco-COUNT METER and Eco-HOUR METER are ideal for maintenance of your facilities and machinery.

FEATURES

additional cabling.

2. Built-in battery

installed anywhere.

(DIN 24 x 48)

3. Economically priced

KC2S



Eco-COUNT METER





Compliance with RoHS Directive

PRODUCT TYPES

1. KC2S Eco-COUNT METER

Product Name	Installation type	Front reset	Measurement count range	Part No.
Eco-COUNT METER main unit*1	Installation frame type*2	Available	0 to 99999999	AKC2421
	One-touch installation type			AKC2621
Intermediate power cable*3	— AKE2811		AKE2811	

Notes: 1. Eco-COUNT METER (AKC2421/AKC2621) is a product package consisting of the main unit, a dedicated current transformer (CT), and trunk cable.

Only the installation frame installation type includes rubber gasket and installation frame.
The maximum allowable current of the intermediate power cable is 15 A.

2. KE2S Eco-HOUR METER

Product Name	Installation type	Front reset	Measurement time range	Part No.
Eco-HOUR METER main unit*1	Installation frame type*2	Available	0 to 99999.9h	AKE2421
	One-touch installation type		0 10 99999.911	AKE2621
Intermediate power cable*3	— AKE2811			

Notes: 1. Eco-HOUR METER (AKE2421/AKE2621) is a product package consisting of the main unit, an exclusive use current transformer (CT), and trunk cable. 2. Only the installation frame type includes rubber gasket and installation frame.

3. The maximum allowable current of the intermediate power cable is 15 A.

SPECIFICATIONS

	Item	Specifications			
Product name		Eco-COUNT METER (Power-on Counter)	Eco-HOUR METER (Power-on Hour Meter)		
Part No.		AKC2421/AKC2621	AKE2421/AKE2621		
No. of digits		8 digits	6 digits		
External power supply		Not required (built-in battery)			
Counting max. speed		2Hz (CT through current minimum power-up time: 250ms, ON:OFF =1:1) -			
Time accuracy		— ±100ppm (25°C)			
Measuremen	t range	0 to 99999999 counts	0 to 99999.9h		
Detection sensitivity (through current)		Counting start: 0.5A to 80A (50/60Hz)*1	Timing start: 0.5A to 80A (50/60Hz)*1		
Detection sensitivity (through curre	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	Counting stop: 0.2A (50/60Hz) or less	Timing stop: 0.2A (50/60Hz) or less		
	Min. input signal width	100ms			
Reset input		Non voltage input using contacts or open collector connection			
	Input method (signal)	• Input impedance, When shorted: Max.10k Ω , When open: Min.750k Ω			
		Residual voltage: Max. 0.5V			
	slay method 7-segment LCD				
Breakdown voltage (initial)			Between live and dead metal parts: 1,000V AC for 1 minute.		
Insulation resistance (initial)		Between live and dead metal parts: Min. 100M Ω (measured at 500 V DC)			
Protective construction*2		IEC Standard IP66 (only front panel with rubber gasket)			
Vibration resistance (Functional)		10 to 55 Hz: 1 cycle/min., signal amplitude of 0.15mm .006inch (10 min. on 3 axes)			
Vibration resistance (Destructive)		10 to 55 Hz: 1 cycle/min., signal amplitude of 0.375mm .015inch (1 hr. on 3 axes)			
Shock resistance (Functional)		Min. 98m 321.522ft/s ² (4 times on 3 axes)			
Shock resistance (Destructive)		Min. 294m 964.567ft/s² (5 times on 3 axes)			
Operating temperature		-10 to +50°C +14 to +122°F (without frost or dew)			
Storage temperature -25 to +			to +65°C -13 to +149°F (without frost or dew)		
Ambient hum	bient humidity 35 to 85% RH (at 20°C non-condensing)		°C non-condensing)		
Battery life*3		7 years (at 25°C 77°F)	10 years (at 25°C 77°F)		
Mass (weight)		Approx. 110g (Dedicated CT included)	Approx. 105g (Dedicated CT included)		
Notes: 1. Ma	ximum cable diameter is 1	0 mm. 3. Batter	ry life is calculated based on the above conditions.		
2. Se	2. See page 13, "NOTES 4. Waterproofing Construction" for details about the protective This is not a guarantee of actual battery life.				
COL	nstruction (IP66).		e use this as a guide for replacing the battery only.		
The extend to the standard structure of the standard structure of the state of the					

the main unit. All Rights Reserved © COPYRIGHT Panasonic Electric Works Co., Ltd.

26/03/2013

5. Two installation methods available (Separate models)

Two installation methods are available: The extremely easy-to-use one-touch installation, and the installation frame installation, used for timers/counters (protective construction IP66). Select the installation type that suits the location.

6. Letter's height is 8.7 mm

The actual battery life may be shortened, depending on the utilization environment of

A large LCD panel is used, with a highly legible 8.7 mm letter's height. 7. Conform to CE marking (EMC directive)

2. Dedicated CT

Item	Specification
Diameter of conductor to be measured	10 dia. (max.)
Breakdown voltage (Initial value)	1,000 Vrms AC for 1min: Between core and output connector terminal
Insulation resistance (Initial value)	Min. 100MΩ: Between core and output terminal (at 500V DC)
Allowable number of detachments/attachments	Approx. 100 times
Vibration resistance (Functional)	10 to 55 Hz: 1 cycle/ min single amplitude of 0.15 mm .006 inch (10 min on 3 axes)
Vibration resistance (Destructive)	10 to 55 Hz: 1 cycle/ min single amplitude of 0.375 mm .015 inch (1 h on 3 axes)
Shock resistance (Functional)	Min. 98 m 321.522 ft./s ² (4 times on 3 axes)
Shock resistance (Destructive)	Min. 294 m 964.567 ft./s ² (5 times on 3 axes)
Operating temperature range	-10°C to +50°C +14°F to 122°F (Without frost or dew)
Storage temperature	-20°C to +60°C -4°F to 140°F (Without frost or dew)
Mass (Weight)	Approx. 55g 1.94oz (trunk cable included)
Ambient humidity	35 to 80% R.H. (at 20°C non-condensing)

Note: For Eco-COUNT METER and Eco-HOUR METER, this CT is supplied together.

APPLICABLE STANDARDS

	(EMI) EN61000-6-4 Radiated emission electric field strength Noise terminal voltage	EN55011 Group 1 Class A EN55011 Group 1 Class A
EMC	(EMS) EN61000-6-2 Static discharge immunity RF electromagnetic field immunity EFT/B immunity Conductivity noise immunity Power frequency electric field immunity	EN61000-4-2 4 kV contact EN61000-4-3 10 V/m AM (80 MHz to 1 GHz) EN61000-4-4 1 kV (Signal line) EN61000-4-6 10 V/m AM (0.15 MHz to 80 MHz) EN61000-4-8 30 A/m (50Hz)
		LN01000-4-0 30 A/III (30112)

ON

PART NAME



(LCD side)

1. Main unit

1) Front reset key

This key resets the count value of Eco-COUNT METER and elapsed time of Eco-HOUR METER. It does not work when the lock switch is ON.

Note that frequent operation may shorten battery life.

2) Lock switch (Refer to chart on left)

Ineffective the front reset key

Note: LCD side is ON (reset ineffective); terminal block side is OFF (reset effective) 2. Dedicated CT





mm inch General tolerance: ±1.0 ±.039

2. Dedicated CT



Note: The trunk cable connects the main unit and dedicated CT. It is included with the main unit.

All Rights Reserved © COPYRIGHT Panasonic Electric Works Co., Ltd. 26/03/2013

Front reset key

DIMENSIONS (Common to Eco-COUNT METER

Notes: 1. * Factory setting. 2. Make the switch setting before installing to panel.

3. Common to Eco-COUNT METER and Eco-HOUR METER.



7 .27

INSTALLATION

1. Panel installation

1) One-touch installation type



2) Installation frame type



3) Panel cut-out dimensions



Note: When installing to a 4.5mm .177 thick panel, remove the rubber spacer first.

1. Panel installation

1) Installation using plastic magnet Attach the unit to the equipment case.



2) Installation via double-sided tape Use this method in places where a plastic magnet cannot be used or where installation strength is insufficient.

 3) Installation via clamp Clamp to one of the cables inside the equipment, etc.



Note: Take careful note of the precautions for use in the catalog or user's manual before using an Eco-COUNT METER or Eco-HOUR METER installed by one of the methods described above.

3. Terminal layout and wiring diagrams (Common to Eco-COUNT METER and Eco-HOUR METER)



Notes: 1. Terminal (2) and (4) are connected inside 2. The CT does not have polarity

OPTIONS

• Intermediate power cable (AKE2811)



Note: We recommend using an intermediate power cable when attaching the dedicated CT to a non-"Y" split power cable

EXPLANATION OF OPERATION

KC2S Eco-COUNT METER 1. The number of power-ons is counted by sending through current through the dedicated CT.

2. When the number of power ons (measured value) reaches the full scale, it reverts to 0, and starts counting again from 0. 3. When the reset terminal input is set to on, the display will read "0". This does not count during reset input. 4. Use the reset key on the front of the unit to reset manually. The display will be blank while the reset key is being pressed.



Note: * If reset input is shut off while CT through current is on, the count will be set to 1.



RESET INPUT (Common to Eco-COUNT METER and Eco-HOUR METER)

1. Contact input

2. Transistor input (NPN transistor)





 Notes: 1. When using contact input, since current flow is small from reset input terminal ③, please use relays and switches with high contact reliability.
When using transistor input, use the following as a guide for which transistors (Tr) to use for inputting. (Collector withstand voltage ≥ 50V, leakage current < 1µA)

NOTES

1. Main unit 1) Reset input

(1) Never apply voltage to reset input. This can cause damage to the internal elements. (2) Since the current flow is very small from reset input terminal (3), please use relays and switches with high contact reliability. When inputting a reset by a transistor's open collector use a transistor for small signals in which I_{CBO} is 1μ A or less and always input with no voltage.

(3) When wiring, try to keep all the input lines to the reset inputs as short as possible and avoid running them together with high voltage and power transmission lines or in a power conduit.

Note that power cable floating capacitance in excess of 500 pF (10m on 2 mm² parallel cables) could cause malfunctions. Take particular care of inter-cable capacitance when using shielded cables.

2) How to reset multiple panel installation type units all at once.



Notes: 1. Use the following as a guide for choosing transistors used for input (Tr). Leakage current < 1μA

 Use as small a diode (D) as possible in the forward voltage so that the voltage between terminals 3 and 4 during reset input meets the standard value (0.5V).

(0.5V). (At IF = 20 μ A, forward voltage 0.1 V or less.)

2. Dedicated CT

 Measured power is AC (50 Hz/60 Hz).
Will not function when used with DC power.
When clamping to the power cable to be measured, clamp only one of the live wires.
Avoid usage that bends the lead wire.
When clamping, make sure that no dust or other foreign matter intercedes between the clamp and contact. Foreign matter could impact detection sensitivity.

3. Insulation sheet

Before using, please pull and remove the insulation sheet in the direction of the arrow. In consideration that the product might be stored for long periods without being used, an insulation sheet is inserted before shipping. Remove the insulation sheet and press the front reset key.

Installation frame type



One-touch installation type



4. Waterproof construction

The operation part is constructed to prevent water from entering the unit and a rubber gasket is provided to prevent water from entering the gap between the unit and the panel cutout.

There must be sufficient pressure applied to the rubber gasket to prevent water from entering.

Be sure to use the mounting screws when using the mounting frame (ATH3803). Attaching the one-touch installation type to a panel will not waterproof the panel surface.



5. Do not use in the following environments1) In places where the temperature changes drastically.

2) In places where humidity is high and there is the possibility of dew. (When dew forms the display may vanish and other display errors may occur.)

6. Cautions regarding battery replacement

 Remove wiring before replacing the battery. You may be electrocuted if you come into contact to a part where high voltage is applied.
Make sure you are not carrying a static electric charge when replacing the battery.
Battery replacement procedure
Installation frame type

- Remove the battery cover ① from the case.
- (2) Remove the battery 2 from the side of the case.

The battery will come loose if you put the battery side face down and lightly shake the unit.

- (3) Before inserting wipe clean the surface of the battery.
 Insert the battery ④ with the + and - sides in the proper position.
- (4) After replacing the battery return the battery cover (5) to the case. Verify that the hook of the battery cover is properly engaged.

Before using press the reset key 6 on the front.

- One-touch installation type
- (1) Using a tool remove the up/down hook of the case ①.
- Pull the unit (2) away from the case.(2) Remove the battery (3) from the side of the unit. Do not touch the display or other parts.
- (3) Before inserting wipe clean the surface of the battery.

Insert the battery (5) with the + and – sides in the proper position.

(4) After replacing the batery return the unit (6) to the case. Verify that the hook of the case has properly engaged.
Before using press the reset key (7) on the

Before using press the reset key \bigcirc on the front.







• One-touch installation type



